

PEOPLES ELECTRICAL · COMMUNICATIONS CONTRACTORS
277 E. Fillmore Avenue, St. Paul, MN 55107
PHONE: 651-227-7711 FAX: 651-227-9684

Panel: PANEL C | Voltage: 120/208
Bus Rating: 225 amp | Fed from:

1	ROUND HOUSE SP	ADMIN. RAMP		2
3	ROUND HOUSE SP	ADMIN. RAMP		4
5	ROUND HOUSE SP	ADMIN. RAMP		6
7	LTS WEST STEPS	Seven Head Southwest THREE HEAD POLE SOUTH		8
9	LTS WEST STEPS	Seven Head Southwest THREE HEAD POLE SOUTH		10
11	LTS WEST STEPS	Seven Head Southwest THREE HEAD POLE SOUTH		12
13	LTS WEST DRIVE WAY	THREE HEAD POLE N.W.		14
15	LTS WEST DRIVE WAY	THREE HEAD POLE N.W.		16
17	LTS WEST DRIVE WAY	THREE HEAD POLE N.W.		18
19	W. STEPS N. FIXTURE	TWO HEAD POLE GOV.		20
21	W. STEPS N. FIXTURE	TWO HEAD POLE GOV.		22
23	W. STEPS N. FIXTURE	~~GOV. PARKING FIXTURE~~ SP		24
25	N.W. HANDY SPOTS	GOV. PARKING FIXTURE		26
27	N.W. HANDY SPOTS	SPARE		28
29	SPARE	SPARE		30
31	SPACE	SPACE		32
33	SPACE	SPACE		34
35	SPACE	SPACE		36
37	SPACE	SPACE		38
39	SPACE	SPACE		40
41	SPACE	SPACE		42

24 HOUR SERVICE - Call 651-227-7711 03/20/2013

1 EXISTING PANELBOARD PANEL-C
NTS

PANEL-C NOTES
1. PANELBOARD SHALL BE DEMOLISHED AS LONG AS CIRCUITS SERVING OCCUPIED AREAS OF THE BUILDING REMAIN OPERATIONAL.



PEOPLES ELECTRICAL · COMMUNICATIONS CONTRACTORS
277 E. Fillmore Avenue, St. Paul, MN 55107
PHONE: 651-227-7711 FAX: 651-227-9684

Panel: L-B-005A | Voltage: 120/208
Bus Rating: 225 amp | Fed from: MDP-B-2

1	50 POST PLUGS	N.E. PARKING LOT LTS		2
3	AIR COND B34	N.W. PARKING LOT LTS		4
5	AIR COND B34	SPRINKLER CONTROL		6
7	RM B31 LTS	RM B-35 RECEP.		8
9	REFRIG	RM B-25 LTS/ HONEYWELL		10
11	OUTSIDE QUARTZ LTS Control	S-1 FILTER		12
13	EXISTING LOAD	EXISTING LOAD		14
15	RM B37 LTS	AIR COND B-37		16
17	UPPER DOME STAIRCASE LTS	AIR COND B-37		18
19	UPPER DOME RECEP.	GFID FLR RECEPS		20
21	SPARE	G-15 BY ELEV		22
23	SPARE	DISPLAY CASE LTS		24
25	QUARTZ LTS GND FLR N.	FLAG CASE RECEP		26
27	QUARTZ LTS GND FLR N.	LTS TUNNEL		28
29	QUARTZ LTS GND FLR N.	F-4 TOILET EXH.		30
31	~~SPARE~~ RECPT. B25B	~~[illegible]~~		32
33	SPARE	SPARE		34
35	SPARE	SPARE		36
37	WELDER	SPARE		38
39	WELDER	SPARE		40
41	WELDER	SPARE		42

24 HOUR SERVICE - Call 651-227-7711 03/20/2013

2 EXISTING PANELBOARD L-005A
NTS

LP-005A NOTES
1. PANELBOARD SHALL BE DEMOLISHED AS LONG AS CIRCUITS SERVING OCCUPIED AREAS OF THE BUILDING REMAIN OPERATIONAL.



PEOPLES ELECTRICAL · COMMUNICATIONS CONTRACTORS
277 E. Fillmore Avenue, St. Paul, MN 55107
PHONE: 651-227-7711 FAX: 651-227-9684

Panel: L-B-005B | Voltage: 120/208
Bus Rating: 225 amp | Fed from: MDP-B-2

1	SPARE	PANEL LP008		2
3	SPARE	PANEL LP008		4
5	SPARE	PANEL LP008		6
7	SPARE	SPARE		8
9	SPARE	SPARE		10
11	SPARE	SPARE		12
13	SPARE	SPARE		14
15	SPARE	SPARE		16
17	SPARE	SPARE		18
19	SPARE	SPARE		20
21	SPARE	SPARE		22
23	SPARE	SPARE		24
25	SPARE	SPARE		26
27	SPARE	SPARE		28
29	SPARE	SPARE		30
31	SPARE	SPARE		32
33	SPACE	SPACE		34
35	SPACE	SPACE		36
37	SPACE	SPACE		38
39	SPACE	SPACE		40
41	SPACE	SPACE		42

24 HOUR SERVICE - Call 651-227-7711 03/20/2013

3 EXISTING PANELBOARD L-005B
NTS

L-005B NOTES
1. PANELBOARD SHALL BE DEMOLISHED AS LONG AS CIRCUITS SERVING OCCUPIED AREAS OF THE BUILDING REMAIN OPERATIONAL.

HGA + SCA
capitol restoration collaborative

Hammel, Green and Abrahamson, Inc.
Architecture | Engineering | Planning
420 5th Street North, Suite 100
Minneapolis, Minnesota 55401
Telephone 612.758.4000
Facsimile 612.758.4199

Schooley Caldwell Associates, Inc.
Architects | Engineers
Planners | Interior Designers
300 Marconi Boulevard
Columbus, Ohio 43215
Telephone 614.628.0300
Facsimile 614.628.0311



KEY PLAN

Minnesota State Capitol Repairs, Restoration, & Preservation

75 Rev Dr. Martin Luther King Jr Blvd
Saint Paul, MN 55155
SCB-02CB0015

I HEREBY CERTIFY THAT THIS PLAN, SPECIFICATION OR REPORT WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MINNESOTA.

NAME: LEIGH HARRISON
DATE: JUNE 14, 2013
REGISTRATION NUMBER: 40448

NO	DESCRIPTION	DATE

REVISION HISTORY - THIS SHEET

HGA NO: 0476-061-00

EXISTING PANELBOARD SCHEDULES - TERRACE NORTH

WORK PACKAGE 1

E602C

© COPYRIGHT HAMMEL, GREEN AND ABRAHAMSON, INC. WWW.HGA.COM