CITY OF LINO LAKES
1189 MAIN STREET
LINO LAKES, MN 55014
(651) 464-5562

FLOW TEST DATA SHEET

DATE: 6/9/11

LOCATION: Commerce Dr & 20th Ave

TIME OF DAY: 2:20 pm

WITNESS: 1. Tim Budig
2. Dave Bruder

STATIC PRESSURE: 63 psi

RESIDUAL PRESSURE: 60 psi

PITOT READING: 52 psi

SIZE OF OPENING: 2½

CHART READING FOR GPM: 1258

INFORMATION SUBMITTED BY: Tim Budig