

Standalone Event – Quality Control Inspection Tests

Please Note: CAZ Depressurization tests are not required in dwellings where all space and water heating plants are electric.

General Tests

- Ambient CO test in kitchen and living area (*BPI 1200 - 2017, 7.3.3*)

Water Heater

- Test for Fuel Leaks (*BPI 1200- 2017, 7.5*)
- Water Heater Combustion Analysis/CO in Flue (*BPI 1200 - 2017, Table 1 for CO thresholds, or AHJ whichever is more stringent*)
 - PVC test holes must be plugged with threaded, knurled screws to create a tight seal
- CAZ Depressurization/Combustion Spillage Test. This test is required on natural draft appliances equipped with a barometric draft control or Category I appliances equipped with a draft hood or connected to a natural draft venting system. (*BPI 1200 - 2017, 7.9*)
- Hot Water Temperature (if replaced or repaired)

Heating Plant

- Test for Fuel Leaks (*BPI 1200- 2017, 7.5*)
- Heating Plant Combustion Analysis/CO in Flue (*BPI 1200 – 2017 Table 1 for CO thresholds, or AHJ whichever is more stringent*)
 - PVC test holes must be plugged with threaded, knurled screws to create a tight seal
 - When a heating system manufacturer does not allow drilling of a metal flue, use a combustion analyzer to test ambient CO at the front of the heating system cabinet and in the closest supply register.
- CAZ Depressurization/Combustion Spillage Test. This test is required on natural draft appliances equipped with a barometric draft control or Category I appliances equipped with a draft hood or connected to a natural draft venting system. (*BPI 1200 - 2017, 7.9*)
- Test Furnace Shutoff Switch
- Heat Rise Test on Furnace
- Ambient CO Test in Mechanical Room(s) and Living Space (*BPI 1200 - 2017, 7.3.3*)
- Smoke Test on Oil Furnace/Oil Water Heater (on units that have been repaired or replaced)

Space Heater (including gas fireplaces)

- Test for Fuel Leaks (*BPI 1200 - 2017, 7.5*)
- Combustion Analysis/CO in Flue (As feasible) (*BPI 1200- 2017 Table 1 for CO thresholds, or AHJ whichever is more stringent*)
- CAZ Depressurization/Combustion Spillage Test (as feasible). This test is required on natural draft appliances equipped with a barometric draft control or Category I appliances equipped with a draft hood or connected to a natural draft venting system. (*BPI 1200 - 2017, 7.9*)