

MINNESOTA VALLEY TESTING LABORATORIES, INC.

MVTL

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 1411 S. 12th St. ~ Bismarck, ND 58502 ~ 800-279-6885 ~ Fax 701-258-9724
 51 W. Lincoln Way ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

**MEMBER
ACIL**

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER

Report Date: 30 Jun 2009

Lab Number: 09-A27114
 Work Order #: 200912-8641
 Account #: 018000

MARY ANWAY
 RED WING CITY OF
 229 TYLER ROAD NORTH
 RED WING MN 55066

Date Received: 23 Jun 2009
 Time Received: 8:50
 Date Sampled: 19 Jun 2009
 Temperature at Receipt: 12.0C

Sample Description: RED WING COMMUNITY WATER
 SUPPLY

Analyte	Results	MCL	RAL	Method	Analyzed	Analyst
Lead	< 0.5 ug/L	15.0	NA	200.8	6/24/09 12:41	RMV
Nitrate	0.55 mg/L as N	10.0	NA	EPA 353.2	6/26/09 9:37	Calculated
Nitrite	< 0.01 mg/L as N	1.00	NA	EPA 353.2	6/24/09 15:48	KAD
Nitrate+Nitrite	0.55 mg/L as N	10.0	NA	EPA 353.2	6/26/09 9:37	AKF
Fluoride	1.1 / 0.45 mg/L	4.00	NA	SM 18th ED 4500-F	6/26/09 3:26	JD
Iron	< 0.015 mg/L	NA	0.300	200.7	6/24/09 14:37	AM
Manganese	0.006 mg/L	NA	0.050	200.7	6/24/09 14:37	AM
pH	7.6 units	NA	6.5 -	SM54500 H-B	6/23/09 11:19	SM
Solids, Total Dissolved	599 mg/L	NA	500	SM 2540C	6/24/09 14:10	LH
Phosphorus, Total	< 0.2 mg/L	NA	NA	EPA 365.1	6/30/09 9:18	AKF
Calcium	68.10 mg/L	NA	NA	200.7	6/24/09 14:37	AM
Magnesium	31.70 mg/L	NA	NA	200.7	6/24/09 14:37	AM
Silicon as Silica	< 10.7 mg/L	NA	NA	200.7	6/29/09 7:37	AM

MCL is defined as the Maximum Contaminant Level allowed by the Safe Drinking Water Act. RAL is the Recommended Allowable Limit. For further information, contact your state or local health department or call the EPA Safe Drinking Water Hotline 1-800-426-4791.

SILICA RESULT AMENDED 1 JUL 09

CERTIFICATION: MN LAB # 027-015-125 WI LAB # 999447680 ND MICRO # 1013-M ND WW/DW # R-040 IA LAB #: 132 I

MVTL

MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 N. Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
1411 S. 12th St. ~ Bismarck, ND 58502 ~ 800-279-6885 ~ Fax 701-258-9724
51 W. Lincoln Way ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885

**MEMBER
ACIL**

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

AN EQUAL OPPORTUNITY EMPLOYER

Report Date: 30 Jun 2009

Lab Number: 09-A27114
Work Order #: 200912-8641
Account #: 018000

MARY ANWAY
RED WING CITY OF
229 TYLER ROAD NORTH
RED WING MN 55066

Date Received: 23 Jun 2009
Time Received: 8:50
Date Sampled: 19 Jun 2009
Temperature at Receipt: 12.0C

Sample Description: RED WING COMMUNITY WATER
SUPPLY

Analyte	Results	MCL	RAL	Method	Analyzed	Analyst
Phosphate, Total	< 0.61 mg/L	NA	NA	EPA 365.1	6/30/09 9:18	Calculated
Hardness, Total	301 mg/L CaCO3	NA	NA	2340.B	6/24/09 14:37	Calculated

** No collection time supplied by the client.

MCL is defined as the Maximum Contaminant Level allowed by the Safe Drinking Water Act. RAL is the Recommended Allowable Limit. For further information, contact your state or local health department or call the EPA Safe Drinking Water Hotline 1-800-426-4791.

SILICA RESULT AMMENDED 1 JUL 09

Page: 2

CERTIFICATION: MN LAB # 027-015-125 WI LAB # 999447680 ND MICRO # 1013-M ND WW/DW # R-040 IA LAB #: 132 I